

Contrast & Compare Planning Process
NCStakeholders - PWG

CALENDAR					
Duke		Progress		Comments	
Planning Calendar					
Modeling/ Assessment/ Solutions/ Budget	Dec-Jan:	Finalize models	Dec-Jan:	Finalize models	
	Feb-Mar:	Perform screen	Feb-Mar:	Perform Near-term(NT) project review	
	Apr-Jun:	Develop solutions	Apr-Jun:	Prioritize projects & submit budget	
	Jul-Aug:	Prioritize projects & develop budget	Jul-Aug:	Perform Long-term(LT) screen	
	September:	Finalize budget			
	Oct-Nov:	Compile input data & develop models	Sep-Nov:	Develop solutions	
			Oct-Nov:	Compile input data & develop models	
			Oct-Mar:	Develop estimates for LT projects	
		Dec:	Budget approved - plan released		

Contrast & Compare Planning Process
NCStakeholders - PWG

CASE DEVELOPMENT			
Duke		Progress	Comments
Reduced External Area Model			
Database cycle	January to June (VSTE Data Bank Process) Companies within VSTE combine new reduced models of their areas coordinating data within VSTE areas. June to December (MMWG Process) Regions combine reduced models of their areas to develop an eastern interconnection model. SERC provides the VSTE Data Bank Cases to the MMWG for this effort. Data is coordinated among regions.	January to June (VSTE Data Bank Process) Companies within VSTE combine new reduced models of their areas coordinating data within VSTE areas. June to December (MMWG Process) Regions combine reduced models of their areas to develop an eastern interconnection model. SERC provides the VSTE Data Bank Cases to the MMWG for this effort. Data is coordinated among regions.	Same
Assumptions	Model long-term firm transmission in model. No partial path reservations modeled.	Model long-term firm transmission in model. No partial path reservations modeled.	Same
Detailed Internal Model ("on-the-shelf cases")			
Cases developed	Summer Peak (for current and next 10 years) Winter Peak (for current and next 10 years) Spring/Fall Peak (for current and next 2 years) Spring Valley (for current and next 3 years)	Summer Peak (for current and next 10 years) Winter Peak (for current and next 10 years)	
Loads	Utilize data from EMS. Loads plus losses at the transmission level will be scaled to match the system forecast for each load level. If conditions warrant, additional cases may be generated to examine the impact of other load levels. Load is not reduced by load management.	Corporate provides PEC load forecast data. PEC distribution organization provides NCPs for all PEC substations for model. Obtains Network Customer's CP forecasts via Network Operating Agreement. Scales PEC area to meet annual forecast without scaling Network Customer data. Load is not reduced by load management.	
Interchange	Long term firm transmission and LSE's DNR projections are modeled in the base case	Models all firm transmission reservations on its OASIS including partial path reservations.	
Behind Meter Gen	Netted with load.	Netted with load.	Same
Duke/PEC Generation	Modeled in detail. Duke's resources dispatched economically. External area dispatch is generally left as in MMWG. All on line generation resources are scaled in the affected control area if interchange adjustments are needed	Modeled in detail. PEC's resources dispatched economically. External area dispatch is generally left as in MMWG. Load of external area is scaled if PEC import adjustments are needed.	
Network Customer Resources	Network customers provide dispatch priority for use in dispatching their resources to their load.	On system generation is modeled based on transmission reservation. Imports are modeled based on transmission reservation.	
Other Non-Duke/PEC Generation	Modeled in detail. IPPs must have an LGIA executed to be in model and they are dispatched at level of approved firm transmission service.	Modeled in detail. IPPs must have an LGIA executed to be in model and they are dispatched at level of approved firm transmission service.	Same
Future Generation	Uses dummy generation in future cases only when additional load serving resources are needed. Dummy generation generally modeled based on generator interconnection queue locations.	Uses dummy generation in future cases only when additional load serving resources are needed. Dummy generation typically modeled on Wake 500 kV bus and named DUMGEN.	
Ratings	Use several different continuous and time-limited emergency line ratings. Rate A - Continuous rating Rate B - 12 hour emergency rating Rate C - Long term emergency rating (based on acceptable loss of life)	Rate A = Rate B = Continuous rating Lines modeled at continuous conductor rating unless ground clearance limited or other equipment (switches, traps, etc.) Transformers modeled at 55 deg rise rating.	

Contrast & Compare Planning Process
NCStakeholders - PWG

ASSESSMENT PRACTICES				
Duke		Progress		Comments
Limits Voltage				
500kV	Maintain minimum of 100%	Maintain minimum of 100%	Same	
230kV	Maintain minimum of 95%	Maintain minimum of 90%		
Allowed Contingency Drop	5%	8%		
Limits Thermal				
Lines Transformers	Do not exceed 100 % of: Rate A for continuous loading, (Category A below.) Rate B for line or 500/230 kV transformer contingencies, (Subset of Category B below.) Rate C for all other transformer, generator and capacitor contingencies. (Remainder of Category B below.) and Base cases + L + L/+ L + T/+ T + T/+ Gm + Gc/+ Gm + L/+ Gm + T contingencies Do not exceed 125 % of Rate A for Category D and bus section/breaker Category C contingencies	Do not exceed 100 % of line rating. (Rate A=Rate B) under normal or contingency conditions (Category A, B, & C below) Do not exceed 100 % transformer 55 deg rise rating (Rate A=Rate B) unless a 65 deg rise rating is available under normal and contingency conditions (Category A, B, & C below.) . Will allow 109% loading of the 55 deg rating under Category B & C conditions if a 65 degree rise rating is available and the bank is determined to be in good condition.		
Other Limits				
Phase Angle	Criteria under evaluation.	Do not exceed 30 degrees phase angle difference across an open terminal.		
Cases Developed				
Years	Screen 3 years out & develop and assess transmission projects.	Assess projects 3 years out to support budget process. Screen 6 years out & develop and assess transmission projects.		
Cases	All generation available (Genration up) base case T case is all generation up case with all firm transmission reservations included Generation maintenance (Gm) cases with a large unit out of service for maintenance and the remainder of Duke's reseources dispatched economically to maintain supply / demand balance	All generation available (Genration up) base case.		
TRM/CBM				
TRM	VACAR reserve sharing amounts reserved	Total of all VACAR reserve sharing plus parallel path bias is reserved (approx 1820 MW). PEC interconnects with all VACAR utilities and studies the import of the full reserved amount on top of other import obgligations.		
CBM	CBM equals 0, therefore none reserved	CBM equals 0, therefore none reserved	Same	
NERC Table I				
Cat A	Base cases (includes the Generation up case, all generator maintenance outage permutations (Gm cases) and one case with all long term firm reservations included (T case))	Generation up		
Cat B	Base cases + generator contingency (Gc) with the amount of Gc lost MW's imported equally among 6 interfaces with appropriate adjustments to Net Interchanges Base cases + line outage Base cases + transformer outage Base cases + capacitor outage	Generation up + line outage or transformer Generator contingency (Gc) with import of TRM (representative of the Gc along with other unit derations) divided in accordance to TRM allocations to individual interfaces with appropriate adjustments to Net Interchanges		
Cat C	Base cases (except T) + bus section Base cases (except T) + breaker Base cases + Line + Line Base cases + Line + Tx Base cases + Tx + Tx Base cases (except T) + Gc + Gc Base cases (except T) + Gm + Line Base cases (except T) + Gm + Tx	Generation up + common tower outages Gc with TRM (as above) + line or transformer outage Gc with TRM (as above) + common tower line outages		
Cat D	Base cases + Common ROW Base cases + substation (one voltage level plus tx's) Base cases + all generation at a station	Beyond scope of CTPP	Same	

Comparison of Duke Energy and Progress Energy Carolinas' CBM/TRM Methodologies

		Duke Energy	Progress Energy Carolinas
CBM	Definition	Same as NERC	Same as NERC
	Value (Imports Only)	Zero on all interfaces	Zero on all interfaces
	Reason	<ul style="list-style-type: none"> - No significant transfer limits - TTC calculations use reduced line ratings (12 hr vs. 1 hr when operating the system) - TTC calculations are based on single worst transmission contingency and adverse generation participation 	<ul style="list-style-type: none"> - Loss-of Load Expectation (LOLE) of 1 day in 10 years requires an emergency transfer capability between 1500 MW and 1800 MW - Required generation reserve is accounted for in TRM
TRM	Definition	Same as NERC	Same as NERC
	Value (Imports)	- Opposing control area's share of the VACAR reserve sharing requirement	- Opposing control area's share of the VACAR reserve sharing requirement [TRM (RS)] plus TRM-Additional Parallel Path Flow Impact [TRM (APPFI)]
	Value (Exports)	- Reserve obligation to meet the VACAR Reserve Sharing Agreement	- Reserve obligation to meet the VACAR Reserve Sharing Agreement
	Reason	- To declare TRM there should be a contractual obligation for reserves, such as the VACAR Reserve Sharing Agreement	- Account for variations in generator dispatch, parallel path flows, and operating reserves, such as the VACAR Reserve Sharing Agreement
	Selling	- Not sold on a firm or non-firm basis, as doing so would degrade system security	- Not sold on a firm or non-firm basis, as doing so would degrade system security
CBM/TRM	Availability to LSEs	<ul style="list-style-type: none"> - Not available for use on a firm basis by market entities, including Duke Energy's affiliated marketer - In response to a generation emergency, the System Operating Center uses TRM for VACAR reserve sharing purposes to benefit all control area LSEs 	<p>TRM available for:</p> <ul style="list-style-type: none"> - Loss of firm resource invoking an Emergency Reserve Sharing Agreement - Declaration of an Energy Emergency Alert (EEA) due to insufficient resources - LSE has exhausted all other options and can no longer provide its customers' expected load requirements.

2005 VACAR Reserve Sharing Obligations

2005 Reserves	Adjusted Peak Load (MW)	Largest Resource (MW)	Contingency Reserve %	Contingency Reserve Commitment
Duke	17926	1135	0.2971	506
PEC	11699	900	0.2129	363
SCPSA	4781	590	0.1136	193
SCE&G	4574	636	0.1172	200
DVP	16507	925	0.2592	441
Total	55487	4186	1.0000	1703

Current Duke Energy and Progress Energy Carolina CBM/TRM Values

Control Area	From	To	CBM	TRM or TRM (RS)	TRM (APPF)
Duke Imports	PJM	Duke	0	0	N/A
	PEC East	Duke	0	363	N/A
	PEC West	Duke	0	0	N/A
	SCE&G	Duke	0	200	N/A
	SCPSA	Duke	0	193	N/A
	TVA	Duke	0	0	N/A
	Southern	Duke	0	0	N/A
	SEPA	Duke	0	0	N/A
	Yadkin	Duke	0	0	N/A
Duke Exports	Duke	PJM	-	0	N/A
	Duke	PEC East	-	306	N/A
	Duke	PEC West	-	200	N/A
	Duke	SCE&G	-	506	N/A
	Duke	SCPSA	-	506	N/A
	Duke	TVA	-	0	N/A
	Duke	Southern	-	0	N/A
	Duke	SEPA	-	0	N/A
	Duke	Yadkin	-	0	N/A
PEC East Imports	PJM	PECE	0	441	487
	Duke	PECE	0	506	0
	SCE&G	PECE	0	200	0
	SCPSA	PECE	0	193	0
PEC East Exports	PEC East	PJM	-	363	0
	PEC East	Duke	-	363	0
	PEC East	SCE&G	-	363	0
	PEC East	SCPSA	-	363	0
PEC West Imports	PJM	PEC West	0	0	42
	Duke	PEC West	0	0	200
	TVA	PEC West	0	0	0
PEC West Exports	PEC West	PJM	-	0	0
	PEC West	Duke	-	0	0
	PEC West	TVA	-	0	0

Comparison of Duke and PEC Line Rating Assumptions and Methodologies

	Duke	PEC
Calculation Method	Not stated	Not stated
Line Altitude	700 ft.	Regional
Line Latitude	35 degrees N	35 degrees N
Line Orientation	Not stated	Not stated
Coefficient of Emissivity	0.7	0.5
Coefficient of Absorption	0.9	0.5
Atmospheric Quality	Clear (100%)	Clear (100%)
Time of Day	14:00 EDT	12:00 EDT
Ambient Air Temperature	40° C (104° F)	35° C (95° F)
		2.0 ft/sec
Ambient Wind Speed	5.0 ft/sec	3.0 ft/sec Coastal
Relative Wind Conductor Angle	45°	90°