

	2006 Reliability Study-Resource Options				
	Recommended Scenarios				
	Alternatives			NET	AGREED TEST LEVEL
	Source	Sink	Sink	CHANGE	
1	PJM (AEP)	DUKE		473	600
2	SOCO	DUKE		564	600
3	TVA	DUKE		464	600
4	SCEG	DUKE		464	600
5	SC	DUKE		464	600
6	CPLE	DUKE		464	600
7	PJM (AEP)		CPLW	535	600
8	PJM (VP)		CPLW	535	600
9	SCEG		CPLW	600	600
10	SC		CPLW	500	600
11	DUKE		CPLW	500	600
12	PJM(AEP/AEP)	DUKE	CPLW	1008	600/600
13	PJM(AEP/VP)	DUKE	CPLW	1008	600/600
14	PJM (AEP)		CPLW	20	20
Not studied					
	SCEG	DUKE	CPLW	1064	600/600
	SC	DUKE	CPLW	964	600/600