

**CAROLINAS TRANSMISSION
PLANNING COORDINATION
ARRANGEMENT
(CTPCA)**

**2014/21 SUMMER PEAK
RELIABILITY STUDY**

FINAL

April 4, 2011

STUDY PARTICIPANTS

Prepared by: **CTPCA Power Flow Studies Group (PFSG)**

<u>Representative</u>	<u>Company</u>
Joey West	Progress Energy Carolinas
Kai Zai	Progress Energy Carolinas
Brian D. Moss, Chair	Duke Energy Carolinas
Bob Pierce	Duke Energy Carolinas (Alternate)
Kale Ford	South Carolina Electric and Gas
Vanessa M. Abercrombie	South Carolina Electric and Gas (Alternate)
William Gaither	South Carolina Public Service Authority
Ricky Thornton	South Carolina Public Service Authority (Alternate)

Reviewed by: **CTPCA Steering Committee (SC)**

<u>Representative</u>	<u>Company</u>
Samuel Waters	Progress Energy Carolinas
A. Mark Byrd	Progress Energy Carolinas
Ed Ernst	Duke Energy Carolinas
Bob Pierce	Duke Energy Carolinas
Brian D. Moss	Duke Energy Carolinas
Clay Young, Chair	South Carolina Electric and Gas
Phil Kleckley	South Carolina Electric and Gas
Tom Abrams	South Carolina Public Service Authority
Jim Peterson	South Carolina Public Service Authority

PURPOSE OF STUDY

The purpose of this study is to assess the existing transmission expansion plans of Duke Energy Carolinas (“Duke”), Progress Energy Carolinas (“Progress”), South Carolina Electric and Gas (“SCEG”), and South Carolina Public Service Authority (“SCPSA”) to ensure that the plans are simultaneously feasible. In addition, this study evaluated any potential joint alternatives identified by the Steering Committee (“SC”) representatives which might improve the simultaneous feasibility of the Participants’ transmission expansion plans. The Power Flow Studies Group (“PFSG”) performed the technical analysis outlined in this study scope under the guidance and direction of the SC.

OVERVIEW OF THE STUDY PROCESS

The scope of the study process included the following steps:

1. Study Assumptions

- Study assumptions selected

2. Study Criteria

- Establish the criteria by which the study results will be measured

3. Case Development

- Develop the models needed to perform the study

4. Study Methodology

- Determine the methodologies that will be used to carry out the study

5. Technical Analysis and Study Results

- Perform the technical analysis (thermal, voltage, and stability as needed) and produce the study results

6. Assessment and Potential Issues Identification

- Evaluate the results to identify potential issues
- Report potential issues to the SC

7. Potential Alternative Assessment

- Evaluate potential joint alternatives as directed by the SC

8. Report on the Study Results

- Combine the study scope and assessment results into a report

STUDY ASSUMPTIONS

- The years studied (study year) are 2014 Summer for a near term reliability analysis and 2021 Summer for a longer term reliability analysis.
- Generation is dispatched for each Participant in the study cases to meet that Participant's peak load in accordance with the designated dispatch order. Participants also provided generation down scenarios for their resources, as requested (e.g., generation outage with description of how generation will be replaced, such as by that Participant's dispatch orders).
- PSS/E and/or MUST are used for the study.
- Load growth assumptions are in accordance with each Participant company's practice.
- Generation, interchange, and other assumptions are coordinated between the Participant companies as needed. The 2010 series LTSG cases for 2014 and 2021 Summer are used as the starting points for study case and interchange development.
- The PFSG use the 2014 and 2021 Summer cases to analyze the existing transmission expansion plans to determine if any reliability criteria violations are created. Based on this analysis, the PFSG will provide feedback to the SC on the simultaneous feasibility of these plans for ensuring the reliability of service. The results of this analysis are included in this report.

STUDY CRITERIA

- NERC Reliability Standards
- SERC requirements
- Individual company criteria (voltage, thermal, stability, short circuit and phase angle)

CASE DEVELOPMENT

- The most current MMWG models are used for the systems external to Duke, Progress, SCEG, and SCPSA as a starting point for the study cases used by the PFSG in their analyses.
- The study cases include the detailed internal models for Duke, Progress, SCEG, and SCPSA and include existing transmission additions planned to be in-service for the given year (i.e. in-service by summer 2014 for 2014S cases as well as in-service by summer 2021 for 2021S cases).
- The Participants coordinated interchange which will include all confirmed long term firm transmission reservations with roll-over rights applicable to the study year(s).

CASE DEVELOPMENT (continued)

- Duke, Progress, SCEG, and SCPSA each created any requested generation down cases from the common study cases and share the relevant cases with each other.

Generation Down Cases Shared

- Duke: Belews Creek 1, Catawba 1, Cliffside 6, Dan River CC, McGuire 1, McGuire 2, Oconee 1, Oconee 3 replaced with internal generation redispatch
- Progress: Brunswick 1, Brunswick 2, Robinson 2, Harris, Roxboro 4 replaced with TRM import
- SCE&G\SCPSA: VC Summer 1 (2014), VC Summer 3 (2021) replaced with internal generation redispatch
- SCPSA: Rainey CC, Cross 3 replaced with internal generation redispatch and import

STUDY METHODOLOGY

- Initially, power flow analyses were performed based on the assumption that thermal and voltage limits are the controlling limits for the reliability plan. Stability, short circuit and phase angle studies were performed if circumstances warrant.
- Duke, Progress, SCEG, and SCPSA exchanged contingency and monitored element files so that each can test the impact of the other systems' contingencies on its transmission system.

TECHNICAL ANALYSIS AND STUDY RESULTS

The technical analysis was performed in accordance with the study methodology. Results from the technical analysis are reported throughout the study area to identify transmission elements approaching their limits such that all Participants are aware of potential issues and appropriate steps can be identified to correct these issues, including the potential of identifying previously undetected problems.

Duke, Progress, SCEG, and SCPSA shared results throughout the study area based on:

- Thermal loadings greater than 90%.
- Voltages less than individual company criteria.

ASSESSMENT AND POTENTIAL ISSUES IDENTIFICATION

Duke, Progress, SCEG, and SCPSA each ran an (N-1) assessment on the base cases and the requested generation down cases using their own internal planning processes. Each Participant's reliability criteria are used for their transmission facilities. Duke, Progress, SCEG, and SCPSA each documented the reliability issues resulting from their assessments. A summary of the potential reliability issues identified in this assessment are found in Tables A-H. These results

were reviewed and discussed among the PFSG and SC to identify potential joint alternatives which might improve the simultaneous feasibility of the Participants' transmission expansion plans.

POTENTIAL ALTERNATIVE ASSESSMENT

- The SC identified two potential joint alternatives assessed by the PFSG.

Potential Joint Alternatives Assessed

- New interconnection between SCPSA's Flat Creek 230 kV station and Duke's Monroe 100 kV station. The studied interconnection is a 30 mile, 230 kV, single-circuit, 1272 ACSR conductor, tied into a new 400 MVA 230/100 kV transformer at Monroe. *ASSESSMENT: This new interconnection does impact power flows on the east side of Charlotte, but only minimal near term benefit was found in the assessment of this potential alternative. A number of Duke's near term projects were found to be accelerated or decelerated 1-2 years, but the more significant benefits were found on projects which are currently projected to be 20-30 years in the future. Duke will continue to assess the benefits of this potential alternative as these future projects move closer to the planning window.*
 - New interconnection between SCPSA's Camden 230/115 kV station and Progress' Camden Junction 115 kV station. The studied interconnection is a 5 mile, 230 kV, single-circuit, 1590 ACSR conductor. *ASSESSMENT: This new interconnection establishes a 230 kV source to Progress's Camden Junction substation which alleviates the overloading issue on the Camden-Camden Junction 115 kV line for the outage of the Camden-Wateree (Duke) 115 kV tie line in the summer of 2021. In addition, the new tie addresses the concern of the ability to adequately service future load growth in the Camden area. Progress will coordinate with SCPSA to assess the feasibility of this project.*
- The PFSG assessed the impact of any potential joint alternatives identified by the SC on the simultaneous feasibility of the Participants' transmission expansion plans.
 - Duke, Progress, SCEG, and SCPSA tested the effectiveness of any potential joint alternatives using the same cases, methodologies, assumptions and criteria described above.
 - If an alternative is assessed to be beneficial to the simultaneous feasibility of the Participants' transmission expansion plans, the impacted Participants would perform a more detailed study to evaluate implementing the alternative under their individual interconnection agreements.

REPORT ON STUDY RESULTS

The PFSG compiled the study scope and assessment results into a report for the SC's review and approval. The final report includes a comprehensive summary of all the study activities.

TABLE A
PROGRESS ENERGY CAROLINAS
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2014 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
Weatherspoon-LOF 115 kV Line	Brunswick 1 Gd (TRM) Weatherspoon-Laurinburg 230 kV Line	Loading (106.2 %)	Operating Guide
Laurinburg 230/115 kV Transformers	Brunswick 1 Gd (TRM) Laurinburg 230/115 kV Transformers	Loading (99.3 %) 55 degree rise	230/115 Bank Replacements [2017]
Falls 230/115 kV Transformer	Brunswick 1 Gd (TRM) Common Tower Area 115 kV Lines	Loading (95.5 %)	Install 2 nd 230/115 kV Bank [2016]
Weatherspoon-Fayetteville 115 kV Line	Brunswick 1 Gd (TRM) Fayetteville Terminal of 115 kV Line	Low Voltage	Fay. Dupont 115kV Capacitor Bank [2014]

TABLE B
PROGRESS ENERGY CAROLINAS
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2021 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
Weatherspoon-LOF 115 kV Line	Brunswick 1 Gd (TRM) Weatherspoon-Laurinburg 230 kV Line	Loading (114.1 %)	Operating Guide
Rockingham-West End 230 kV West Line	Harris Gd (TRM) Rockingham-West End 230 kV East Line	Loading (109.7 %)	Operating Guide
Florence-Marion 115 kV Line	Brunswick 2 Gd (TRM) Florence-Latta 230 kV Line	Loading (102.2 %)	Florence-Marion 230 kV Line [2020]
Weatherspoon-Marion 115 kV Line	Brunswick 1 Gd (TRM) Weatherspoon-Latta 230 kV Line	Loading (100.1%)	Operating Guide

TABLE B (continued)
PROGRESS ENERGY CAROLINAS
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2021 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
Camden-Camden Junction 115 kV Line	Robinson 2 Gd (TRM) Camden-Camden Dupont 115 kV Line	Loading (99.4 %)	To Be Followed
Durham-RTP 230 kV Line	Harris Gd (TRM) Common Tower Method-Durham 230 kV Lines	Loading (94.3 %)	Reconductor [2020]

TABLE C
DUKE ENERGY CAROLINAS
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2014 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
McGuire-Riverbend 230 kV Line 2	Catawba 1 Gm McGuire-Riverbend 230 kV Line 1	Loading (99.8 %)	Generation ReDispatch [2015]
Horseshoe-Nix Rd Tap 100 kV Line	Cliffside 5 Gm Horseshoe-Asheville Hwy 100 kV Line	Loading (92.5 %)	4.41 miles 477 ACSR Reconductor [2020]
McGuire 500/230 kV Transformer A1	McGuire 1 Gm Woodleaf-Pleasant Garden 500 kV Line	Loading (91.1 %)	New 500/230 kV Substation or 230 kV Switched Reactor [2021]

TABLE D
DUKE ENERGY CAROLINAS
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2021 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
Peach Valley-Riverview 230 kV Line 2	Oconee 1 Gm Peach Valley-Riverview 230 kV Line 1	Loading (111.8 %)	19.33 miles 795 ACSR Reconductor [2021]
Cliffside-Broad River 16 100 kV Line	Oconee 1 Gm Tiger 230/100 kV Transformer 6	Loading (103.7 %)	13.92 miles 2/0 Cu Reconductor [2021]
Lakewood-Riverbend 100 kV Line	Buck CC Gm Lakewood-Belhaven 100 kV Line	Loading (105.1 %)	10.64 miles 336 ACSR Reconductor [2021]
Great Falls-Wateree 100 kV Line 2	Harris Gd (TRM) Great Falls-Wateree 100 kV Line 2	Loading (101.2 %)	Limit Duke's Wateree Generation [2021]

TABLE D (continued)
DUKE ENERGY CAROLINAS
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2021 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
Shelby-Transco Tap White 100 kV Line	Catawba 1 Gm Shelby-Transco Tap Black 100 kV Line	Loading (107.7 %)	5.01 miles 2-336 ACSR Reconductor [2021]
Lakewood 230/100 kV Transformer	Catawba 1 Gm Lakewood 230/100 kV Transformer	Loading (117.5 %)	Add Transformer Capacity [2021]
McAdenville-Rankin Tap 100 kV Line	Belews Creek 1 Gm Riverbend-Lumber Lane Tap 100 kV Line	Loading (106.3 %)	3.39 miles 795 ACSR Reconductor [2021]
Lawsons Fork-Pinewood 100 kV Line	Oconee 1 Gm Lawsons Fork-Pinewood 100 kV Line	Loading (113.5 %)	1.08 miles 477 ACSR Reconductor [2021]

TABLE D (continued)
DUKE ENERGY CAROLINAS
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2021 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
Newport-Wylie 100 kV Line	Allen 5 Gm Morning Star 230/100 kV 4 Morning Star-Newport 230 kV Line	Loading (100.3 %)	7.47 miles 795 ACSR Reconductor [2021, 2024]
Parkwood 500/230 kV Transformer 5	Roxboro 4 Gd (TRM) Parkwood 500/230 kV Transformer 6	Loading (100.6 %)	Operating Guide [2021]
Allen 230/100 kV Transformer 6	Allen 5 Gm Allen 230/100 kV Transformer 2	Loading (102.4 %)	Add Transformer Capacity [2022]

TABLE E
SOUTH CAROLINA ELECTRIC AND GAS
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2014 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
McIntosh-Jasper Tap 115 kV Line (Southern/SCE&G)	Cross 3 Gd Jasper-Yemassee 230 kV Line	Loading (100.6 %)	Jasper-Okatie-Yemassee 230 kV Line
Lyles-Williams St 115 kV Line	Cross 3 Gd Lyles-Edenwood 230 kV Line	Loading (104.3 %)	Line Upgrade
Georgia Pacific Tap	Cliffside 6 Gm Saluda-Georgia Pacific Tap 115 kV Line	High Voltage	SCE&G, SCPSA, and Duke are jointly investigating

TABLE F
SOUTH CAROLINA ELECTRIC AND GAS
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2021 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
McIntosh-Jasper Tap 115 kV Line (Southern/SCE&G)	Belews Creek 1 Gm McIntosh-Purrysburg 230 kV Line (Southern/SCPSA)	Loading (118.8 %)	SCE&G and Southern Company are jointly investigating
Summerville 230/115 kV Transformer 2	Cross 3 Gd Summerville 230/115 kV Transformer 1	Loading (100.1 %)	Upgrade Transformer to 336 MVA and leave 224 MVA as in-service spare
Parr-Winnsboro 115 kV Line	Pineland-North Point 115 kV Line	Loading (100.4 %)	Winnsboro or Blythewood Substation
Georgia Pacific Tap	Cross 3 Gd Saluda-Georgia Pacific Tap 115 kV Line	High Voltage	SCE&G, SCPSA, and Duke are jointly investigating

TABLE G
SOUTH CAROLINA PUBLIC SERVICE AUTHORITY
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2014 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
Winyah-Campfield 230 kV Line	Brunswick 1 Gd (TRM) Winyah-Hemingway 230 kV Line	Loading (96.9 %)	Bucksville 230-115 kV Sub. [2015] Winyah-Bucksville 230 kV Line [2016] Bucksville-Garden City 115 kV Line [2017]
Arcadia-Parkersville 115 kV Line	Brunswick 2 Gd (TRM) Perry Road-Campfield 230 kV Line	Loading (91.8 %)	Bucksville 230-115 kV Sub. [2015] Winyah-Bucksville 230 kV Line [2016] Bucksville-Garden City 115 kV Line [2017]
Georgetown-Campfield 3 115 kV Line	McGuire 1 or 2 Gm Winyah-Campfield 230 kV Line	Loading (115.2 %)	Bucksville 230-115 kV Sub. [2015] Winyah-Bucksville 230 kV Line [2016] Bucksville-Garden City 115 kV Line [2017]

TABLE G (continued)
SOUTH CAROLINA PUBLIC SERVICE AUTHORITY
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2014 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
Georgetown-Winyah 1 115 kV Line	Brunswick 1 or 2 Gd (TRM) Georgetown-Winyah 2 115 kV Line	Loading (93.0 %)	Bucksville 230-115 kV Sub. [2015] Winyah-Bucksville 230 kV Line [2016] Bucksville-Garden City 115 kV Line [2017]

TABLE H
SOUTH CAROLINA PUBLIC SERVICE AUTHORITY
SUMMARY OF POTENTIAL RELIABILITY ISSUES
2021 SUMMER PEAK

Element	Contingency	Potential Issue	Potential Solution
Winyah-Campfield 230 kV Line	Brunswick 2 Gd (TRM) Georgetown-Campfield 2 115 kV Line	Loading (92.5 %)	Evaluating